



TIM 1 = ON-DELAY TIMER PN 16023 (SET TO 60 SECS)

TIM 2 = ON-DELAY TIMER PN 16023 (SET TO 15 SECS)

TERM 9 IS ON WHEN HUMIDAIRE PUMP IS ON

TERM 10 IS NEUTRAL

OPERATION NOTE: OPERATOR WILL OBSERVE SCALE FORMATION IN WATER TANK. SET TIM 2 VALVE TO MIN(NO LESS THAN 5 SECS) IN ORDER TO PREVENT BUILDUP. 10-15 SECS IS A GOOD INITIAL VALVE TO START WITH.

SAMUEL JACKSON, INC.	
PURGE TIMER ASSEMBLY	
HU-60-1106C	
GAS-FIRED HUMIDAIRE UNIT	
10-20730	5-02